

NORTH CHARLESTON SEWER DISTRICT PRETREATMENT PROGRAM LOCAL LIMITS

PARAMETER	MONTHLY AVERAGE (mg/l)	DAILY MAX (mg/l)
Acenaphthene	10	15
Acrylonitrile	1.0	1.5
Aldrin	0.001	0.0015
Anthracene	20	30
Antimony	3.0	5.0
Arsenic	1.1	1.7
Barium	20	30
Benzene	20	30
Benzene, 1,2,4-Trichloro	20	30
Benzene, 1,2-Dichloro	20	30
Benzene, 1,3-Dichloro	20	30
Benzene, 1,4-Dichloro	20	30
Benzene, Chloro	20	30
Benzene, Ethyl	30	50
Benzene, Hexachloro	0.001	0.0015
Benzene, Nitro	30	50
Benzidine	0.0029	0.0037
Beryllium	1.3	2.0
BHC (alpha)	0.07	0.09
BHC (beta)	0.12	0.21
BNA (total)	10	15
Butadiene, Hexachloro	10	15
Cadmium	5.0	7.5
Carbon Tetrachloride	10	15
Chlordane	0.012	0.015
Chloroform	30	50
Chromium (total)	2.5	3.8

NORTH CHARLESTON SEWER DISTRICT PRETREATMENT PROGRAM LOCAL LIMITS

Copper	0.5	0.8
Cyanide	0.5	0.75
DDT	0.0001	0.00015
4,6-Dinitro-2-Methylphenol	15	22.5
Endrin	0.0001	0.00015
Ethane, 1,1,1-Trichloro	5.0	7.5
Ethane, 1,1,2-Trichloro	5.0	7.5
Ethane, 1,1-Dichloro	5.0	7.5
Ethane, 1,2-Dichloro	0.6	0.9
Ethane, Hexachloro	5.0	8.0
Ether, bis(2-Chloroethyl)	0.8	1.2
Ethylene, 1,1-Dichloro	5.0	7.5
Ethylene, 1,2-trans-Dichloro	5.0	7.5
Ethylene, Tetrachloro	10	15
Ethylene, Trichloro	10	15
Fluoranthene	10	15
Fluorene	10	15
Formaldehyde	67	100
HEM	200	300
Isophorone	40	60
Lead	1.0	1.5
Lindane (γ BHC)	0.01	0.015
Mercury	0.005	0.0075
Methyl Chloride	10	15
Methylene Chloride	10	15
Naphthalene	10	15
Nickel	2.8	4.3
PAH	-	30

NORTH CHARLESTON SEWER DISTRICT PRETREATMENT PROGRAM LOCAL LIMITS

Phenanthrene	10	15
Phenols (Total)	33	50
Phenol, 2-Nitro	20	30
Phenol, 4-Nitro	20	30
Phenol, 2,4,6-Trichloro	10	15
Phenol, Dimethyl	30	50
Phenol, Pentachloro	11	17
Phthalate, bis(2-Ethylhexyl)	10	15
Phthalate, Diethyl	30	50
Phthalate, Di-n-butyl	30	50
Phthalate, Di-n-octyl	10	15
Phthalate, Dimethyl	67	100
Propane, 1,2-Dichloro	5.0	7.5
Propylene, 1,3-Dichloro	10	15
Pyrene	10	15
Selenium	0.8	1.2
SGT-HEM	100	150
Silver	2.5	3.8
Thallium	1.0	1.5
Toluene	40	60
TTO (metal finishing)	-	2.13
Vinyl Chloride	10	15
VOC (total)	15	30
Zinc	1.8	2.4