



NOTES:

1. OPEN CUT INSTALLATIONS WILL REQUIRE 12 GAUGE COPPER WIRE.
2. TRENCHLESS INSTALLATIONS WILL REQUIRE 10 GAUGE STAINLESS STEEL WIRE.
3. CONTRACTOR SHALL INSTALL DUMMY VALVE BOXES AT INTERVALS NO GREATER THAN 1000 FEET, INCLUDING ONE AT THE PUMP STATION AND ONE AT THE DISCHARGE POINT.

TRACER WIRE AND METALLIC
WARNING TAPE FOR FORCE MAINS
N.T.S.



7255 STALL ROAD, NORTH CHARLESTON, SC 29406
PH: (843) 764-3072 FAX: (843) 764-2655

N.C.S.D. STANDARD DETAILS

REV. DATE: JUNE 2019	DWG#:	FM-002
----------------------	-------	--------