



- NOTES:**
1. NEOPRENE BOOT, KOR-N-SEAL OR EQUAL, TO BE USED ON ALL PRECAST MANHOLES WITH ALL TYPES OF PIPES.
 2. NONSHRINK GROUT INSIDE MANHOLE TO MATCH FINISH WALL.
 3. MANHOLE STEPS ARE NOT ALLOWED.

STANDARD PRECAST CONCRETE MANHOLE DETAIL
N.T.S.

**NORTH CHARLESTON
SEWER DISTRICT**

7255 STALL ROAD, NORTH CHARLESTON, SC 29406
PH: (843) 764-3072 FAX: (843) 764-2655

N.C.S.D. STANDARD DETAILS

REV. DATE: JUNE 2019	DWG#: GS-001
----------------------	--------------