



DROP INVERT MAY COME IN ON TOP OF INVERT SHOULDER. HOWEVER A CHANNEL TO DIRECT THE FLOW TOWARD THE OUTLET PIPE SHALL BE FORMED AROUND THE BEND.

STANDARD INSIDE DROP MANHOLE DETAIL  
N.T.S.



**NORTH CHARLESTON  
SEWER DISTRICT**

7255 STALL ROAD, NORTH CHARLESTON, SC 29406  
PH: (843) 764-3072 FAX: (843) 764-2655

**N.C.S.D. STANDARD DETAILS**

REV. DATE: JUNE 2019	DWG#: GS-003
----------------------	--------------