



NOTES:

1. UNLESS OTHERWISE NOTED, ALL CONCRETE SHALL DEVELOP A MINIMUM COMPRESSIVE STRENGTH OF 4000 PSI IN 28 DAYS.
2. ALL DEFORMED REINFORCING BARS SHALL BE NEW BILLET STEEL CONFORMING TO ASTM A615, LATEST REVISION, GRADE 60.
3. ALL DETAILING, FABRICATION, AND PLACING OF REINFORCING STEEL SHALL CONFORM TO THE "MANUAL OF STANDARD PRACTICE FOR DETAILING REINFORCED CONCRETE STRUCTURES"--ACI 315.
4. BOND THE EQUIPMENT GROUNDING CONDUCTOR(S) ROUTED WITH THE LIGHTING CIRCUIT TO THE INTERNAL GROUND LUG WELDED TO THE INTERIOR OF THE POLE WITH AN EXOTHERMIC CONNECTION.

LIGHT POLE BASE DETAIL
N.T.S.



7255 STALL ROAD, NORTH CHARLESTON, SC 29406
PH: (843) 764-3072 FAX: (843) 764-2655

N.C.S.D. STANDARD DETAILS

REV. DATE: JUNE 2019	DWG#: PS-008
----------------------	--------------