



Safeguarding today, preserving tomorrow



3955 Faber Place Drive, Suite 300, N. Charleston, SC 29405
Tel: 843.881.9804

NORTH CHARLESTON SEWER DISTRICT

PURCHASING DEPARTMENT

**Purchasing Manager: Kimberly Caver, P.O. Box 63009 or
7225 Stall Road (BLDG C), North Charleston, SC 29419
PHONE: (843) 764-2653**

TO: All Prospective Offerors

FROM: Kimberly Caver, Purchasing Manager

RFP TITLE: Sunnyside Pump Station Replacement

ADDENDUM NUMBER 3 – May 22, 2025 – 1 PAGE

Acknowledge receipt of this addendum by inserting its number and date in the space provided on the BID FORM, Section 00 41 00 Page 2, for receipt of Addenda. Failure to do so may subject Bidder as non-responsive. This addendum should be attached to and become part of the Contract Documents.

Specifications:

1. Section 33 31 13.16, Polyvinyl Chloride Gravity Pipe and Fittings (SDR-35), make the following revisions:
 - a. **REPLACE** “(SDR-35)” in the title with “(SDR-26)”.
 - b. **REVISE** paragraph 2.01.A., to read:
“PVC nonpressure sewer pipe 4-inches through 15-inches shall conform to ASTM D3034, 18-inches through 60-inches diameter to ASTM F679, all with SDR of 26 unless noted, and shall meet the specific requirements and exceptions to the aforementioned specifications that follow.”

END ADDENDUM NUMBER 3
