



Addendum No. 1

December 3, 2025

CIP# 2643000-Engineering for Pipe Supports for SGM-04718
North Charleston Sewer District
North Charleston, SC

Addendum No. 1 is hereby incorporated and made part of the RFQu Documents
Except as specifically modified by this document, all other terms and conditions remain in full
force and effect.

COMMENTS


1. The final proposal should include two (2) alternate designs for items 3-6:
 - a. Alternate #1: This proposal is for the replacement and/or rehabilitation of existing pipe supports and CIPP of the existing 12-inch gravity main.
 - b. Alternate #2: This proposal is for the abandonment of the aerial section of the existing 12-inch gravity main, installation of one (1) precast manhole, and approximately 240 LF of 12-inch gravity main.
2. The 12-inch gravity main enters the 54-inch gravity main at approximately the 9:00 position, as seen in the video screenshot. Invert elevations are provided on record drawing 476.

GENERAL

1. See attached Pre-proposal Site Visit sign in sheet
2. See attached 54-inch video screenshot
3. See attached 476

The due date and time is NOT changed. It remains December 30, 2025, at 2:00 PM. This Addendum No. 1 must be acknowledged in the submission documents.

END OF ADDENDUM No. 1



0222.8

